



GOVERNMENT OF KARNATAKA

Office of the District Fire Officer,
Karnataka State Fire Service
Fire Station
BAGALKOT-587 102

C.NO/ 386/ADV/DFO/BAGALKOT/2024

Date.....28/05/2024

To,
Managing Trustee,
Sri Mata Educational & Rural
Development Trust @, Hungund.
Bagalkot -District.

Sir,

Sub : Issue of 'Fire safety recommendation' to S.S. Kadapatti International Public School, at Sy No : 319/1B/3, Hungund, Dist- Bagalkot.
Ref: 1) Applicant request letter Dated 23/05/2024.
2) No.GBC(2)044/2020-21 Dated 18/06/2022 S.O No.156-B.

..*..*..*..*..*..*..

With reference to the subject above cited, the premises of S.S. Kadapatti International Public School, building consisting with Ground floor + 03 Upper floor situated at Sy No : 319/1B/3, Hungund, Bagalkot District, was inspected by me on 23/05/2024 with respect to Fire prevention, Fire fighting and Evacuation measures to be complied in the above premises and has submitted the details as under.

ANNEXURE-1


(Up to 14.99 mtrs. in height)

Group B Education Building

NBC-2016, Part-4, Table 7 (11) 3.1.3 Group B Educational Buildings sub division B1 & B2.
(These condition are indicative and not exclusive all relevant provisions related to fire and life safety of NBC 2016 are mandatory)

A. Details of the building / premises :-

01	Name and Address of the Applicant.	:	Managing Trustee, Sri Mata Educational & Rural Development Trust @, Hungund. Bagalkot -District.
02	Name and Address of the premises.	:	Sri Mata Educational & Rural Development Trust @, Hungund. S.S. Kadapatti International Public School, Sy No : 319/1B/3, Hungund, Dist- Bagalkot.
03	Name and address of the Building owner	:	Sri Basavaraj S Kadapatti Hungund. Bagalkot -District.
04	Number of buildings	:	01 Building
05	Number of floors	:	Ground+03 upper floors
06	<u>Floor-wise details of occupancy:-</u>		
	Ground Floor	:	Class Room-08.



	First Floor	:	Class Room-08.
	Second Floor	:	Room-11.
	Third Floor	:	Room-08.
07	Height of the building	:	14.60 mtrs
08	Site area	:	2.5 Acre
09	Built-up area of each floor:-		
	Ground Floor	:	864.24 Sq. Mtrs.
	First Floor	:	864.24 Sq. Mtrs.
	Second Floor	:	864.24 Sq. Mtrs.
	Third Floor	:	864.24 Sq. Mtrs.
10.	Total built-up area	:	3456.96 Sq. Mtrs.
11.	Surrounding properties:-		
	East	:	S.B.Kadapatti Land.
	West	:	N.A Land.
	North	:	Canal.
	South	:	Road.
12.	Set-back area available around the building :-		
	East	:	20.00 Mtrs.
	West	:	10.00 Mtrs
	North	:	Play Ground
	South	:	05.00 Mtrs.
Allowed setbacks (open space) should be maintained free from further obstruction / construction			

Note : Recommended to provide and maintain setbacks as per Local ZR.

B. On inspection of this Educational premises, the following fire prevention, fire fighting and evacuation measures recommended are considered absolutely essential from fire safety point of view :

Sl. No. (1)	Details (02)	Existing (03)	Recommendations (04)																		
01.	Accessibility to the premises	The premise is abutting by 09.00 mtrs. Wide hard surfaced road located on Southern side.	Adequate																		
02.	No. of entrances	01 No entrance of 05.75 mtrs & exit of 03.00 mtrs wide is provided.	Adequate																		
03.	No. of staircases available	<table border="1"> <tr> <td>Nos. of staircases</td> <td>:</td> <td>02</td> </tr> <tr> <td>Width of staircases</td> <td>:</td> <td>1.25 mt</td> </tr> <tr> <td>Width of treads</td> <td>:</td> <td>30 cm</td> </tr> <tr> <td>Height of risers</td> <td>:</td> <td>15 cm</td> </tr> <tr> <td>Nos. of riser per flight</td> <td>:</td> <td>9=11 no.</td> </tr> <tr> <td>Height of handrails</td> <td>:</td> <td>0.90 mt</td> </tr> </table>	Nos. of staircases	:	02	Width of staircases	:	1.25 mt	Width of treads	:	30 cm	Height of risers	:	15 cm	Nos. of riser per flight	:	9=11 no.	Height of handrails	:	0.90 mt	Recommended to provide staircases maintaining travel distance with 22.50 mtrs. With minimum 02.00 mtrs. Width, 30 cm treads width, 15 cm treads height, 1 mtr. Handrail.
Nos. of staircases	:	02																			
Width of staircases	:	1.25 mt																			
Width of treads	:	30 cm																			
Height of risers	:	15 cm																			
Nos. of riser per flight	:	9=11 no.																			
Height of handrails	:	0.90 mt																			



Bank's copy



ಚಲನ್ ಬಾಲ್ಡಿ ಅವಧಿ Challan Validity	ಜಿಲ್ಲೆ District	ಇಲಾಖೆ Department	ಡಿಡಿ ಕಛೇರಿ DDO Office	
7 Days	BAGALKOT	DEPARTMENT OF KARNATAKA FIRE & EMERGENCY SERVICES	DISTRICT FIRE OFFICE, BAGALKOTE	
ವರ್ಗ Category	ದಿನಾಂಕ Date	ಚಲನ್ ಉಲ್ಲೇಖ ಸಂಖ್ಯೆ Challan Reference Number	ಡಿಡಿ ಕೋಡ್ DDO Code	
Government	28/05/2024	CR0524007000254627	140380	
ಸಂದಾಯದಾರನ ಹೆಸರು Remitter Name	Managing Trustee Sri Mata Education And Rural Development Trust			
ವಿಳಾಸ Address	At hungund Tq Hungund			
ಉದ್ದೇಶ Purpose	ಲೆಕ್ಕ ಶೀರ್ಷಿಕೆ Head of Account	ಉಪ ಉದ್ದೇಶದ ಹೆಸರು Sub Purpose Name	ಉದ್ದೇಶ ನಿರ್ದಿಷ್ಟ ಐಡಿ Purpose Specific ID	ಮೊತ್ತ Amount
COLLECTION OF FEES AND OTHER RECEIPTS FROM FIRE DEPARTMENT	0070-60-109-0-02-000	12.FOR ISSUE OF ADVISE ON FIRE PREVENTION AND FIRE FIGHTING FOR NON HIGH RISE BUILDINGS.	NA-	25600
ಸಂದಾಯದ ಬ್ಯಾಂಕ್ Remittance Bank	STATE BANK OF INDIA	ಒಟ್ಟು ಮೊತ್ತ Grand Total	25600	
ಪಾವತಿ ಕಂತ Payment Status	Payment Yet To Be Made At Agency Bank	ಒಟ್ಟು ಮೊತ್ತ ಲಕ್ಷರಗಳಲ್ಲಿ Total Amount in Words	Twenty Five Thousand Six Hundred Only	
ಪಾವತಿ ವಿವರಗಳು/Payment Details				
ಪಾವತಿ ವಿಧ Payment Mode	Cash T- 256319836			